

UZINA GRĂNICERI 2019

Valori max. admise Lege 458 / 2002	Turb	Cond	pH	NH4	NO2	CCOMn	Dt	Cl	SO4	NO3	Fe	Mn	As	Cl rez	Colonii bact. 22 gr. C	Colonii bact. 37 gr. C	Coli-formi	E. coli	Entero-coci	Miros	Gust	culoare
		5 NTU	2500 μS/cm	6,5-9,5	0,5 mg/l	IR 0,1 R 0,5 mg/l	5 mg/l O ₂	20 ° germ	250 mg/l	250 mg/l	50 mg/l	200 μg/l	50 μg/l	10 μg/l	IR>0,5 R<0,1 mg/l	0 / ml	20 / ml	0 /100 ml	0 /100 ml	0 /100 ml	Acceptabila consumatorilor si nici o modificare anormala	Acceptabila consumatorilor si nici o modificare anormala

Grăniceri - intrare retea

Data	Cod	Turb	Cond	pH	NH4	NO2	CCOMn	Dt	Cl	SO4	NO3	Fe	Mn	As	Cl rez	Colonii bact. 22 gr. C	Colonii bact. 37 gr. C	Coli-formi	E. coli	Entero-coci	miros	gust	culoare
21-ian	157	0,237	496	8,41	1,25	0,01	0,90	30,04	20,35	3,27	7,71	24	29		0,02						0	0	0
28-ian	227	0,427	429	7,73	0,94	0,00	0,70	9,08	13,75	2,05	0,25				0,20	0	2	0	0	0	0	0	0
30-ian	263	0,484	427	8,03	1,02	0,00	0,79	8,83	14,18	2,31	0,30			4	0,19						0	0	0
12-mar	613	0,265	490	8,06	1,00	0,00	0,60	14,56	13,77	3,73	1,20			5	0,03	0	0	0	0	0	0	0	0
19-mar	665														0,12								
26-mar	708				1,08																		
11-apr	828				0,86																		
22-mai	1308	0,354	410	8,02	2,20	0,09	0,77	9,10	11,89	2,23	1,05	21	25	6	0,10	17	0	0	0	0	0	0	0
28-aug	2206	0,47	390	7,26	1,04	0,00	1,81	8,66	10,48	1,00	0,58	61	31		0,00	20	20	30	0	0	0	0	0
13.nov.	2846	1,10	399	7,74	1,61	0,10	0,70	9,15	12,25	4,50	0,30	25	66		0,00	9	4	0	0	0	0	0	0
16-dec	3153														0	0	0	0	0	0			
Min		0,237	390	7,26	0,86	0	0,6	8,66	10,48	1	0,25	21	25	4	0,00	0	0	0	0	0	0	0	0
Med		0,48	434	7,89	1,22	0,03	0,90	12,77	13,81	2,73	1,63	33	38	5	0,08	8	4	5	0	0	0	0	0
Max		1,1	496	8,41	2,2	0,1	1,81	30,04	20,35	4,5	7,71	61	66	6	0,20	20	20	30	0	0	0	0	0
Nr. probe		7	7	7	9	7	7	7	7	7	7	4	4	3	8	6	6	6	6	6	7	7	7
Depășiri		0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	1	0	0	0	0	0
% depășiri		0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	25%	0%	0%	0%	0%	17%	0%	0%	0%	0%	0%

Grăniceri - Rețea Sc Generala

Data	Cod	Turb	Cond	pH	NH4	NO2	CCOMn	Dt	Cl	SO4	NO3	Fe	Mn	As	Cl rez	Colonii bact. 22 gr. C	Colonii bact. 37 gr. C	Coli- formi	E. coli	Entero- coci	miros	gust	culoare
21-ian	158	0,858	470	8,48	0,63							19	27		0,00						0	0	0
28-ian	228	0,555	421	7,71	0,74										0,16	0	1	0	0	0	0	0	0
30-ian	264	0,398	414	7,90	0,98									4	0,15						0	0	0
22-mai	1309	0,488	412	8,11	2,53							35	27	6	0,10	12	0	0	0	0	0	0	0
Min		0,398	412	7,71	0,63							19	27	4	0,00	0	0	0	0	0	0	0	0
Med		0,57	429	8,05	1							27	27	5	0,10	6	1	0	0	0	0	0	0
Max		0,858	470	8,48	2,53							35	27	6	0,16	12	1	0	0	0	0	0	0
Nr. probe		4	4	4	4							2	2	2	4	2	2	2	2	2	4	4	4
Depășiri		0	0	0	0							0	0	0	0	0	0	0	0	0	0	0	0
% depășiri		0%	0%	0%	0%							0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%

TOTAL IR + CR

Data		Turb	Cond	pH	NH4	NO2	CCOMn	Dt	Cl	SO4	NO3	Fe	Mn	As	Cl rez	Colonii bact. 22 gr. C	Colonii bact. 37 gr. C	Coli- formi	E. coli	Entero- coci	miros	gust	culoare
Min		0,237	390	7,26	0,63	0	0,60	8,66	10,48	1,00	0	19	25	4	0,00	0	0	0	0	0	0	0	0
Med		0,526	432	7,97	1,22	0	0,90	12,77	13,81	2,73	1,63	30	32	5	0,09	7	2	3	0	0	0	0	0
Max		1,1	496	8,48	2,53	0,1	1,81	30,04	20,35	4,5	7,71	61	66	6	0,20	20	20	30	0	0	0	0	0
Nr. probe		11	11	11	13	7	7	7	7	7	7	6	6	5	12	8	8	8	8	8	11	11	11
Depășiri		0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	1	0	0	0	0	0
% depășiri		0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	17%	0%	0%	0%	0%	13%	0%	0%	0%	0%	0%