

UZINA SĂVĂRȘIN 2019

Valori max. admise Lege 458 / 2002	Turb	Cond	pH	NH4	NO2	CCOMn	Dt	Cl	SO4	NO3	Fe	Mn	As	Cl rez	Colonii bact. 22 gr. C	Colonii bact. 37 gr. C	Coli-formi	E. coli	Entero-coci	Miros	Gust	culoare
		5 NTU	2500 μS/cm	6,5-9,5	0,5 mg/l	IR 0,1 R 0,5 mg/l	5 mg/l O ₂	20 ° germ	250 mg/l	250 mg/l	50 mg/l	200 μg/l	50 μg/l	10 μg/l	0<0,5 R>0,1 mg/l	/ ml	/ ml	0 /100 ml	0 /100 ml	0 /100 ml	Acceptabila consumatorilor si nici o modificare anormala	Acceptabila consumatorilor si nici o modificare anormala

SĂVĂRȘIN - intrare rețea

Data	Cod	Turb	Cond	pH	NH4	NO2	CCOMn	Dt	Cl	SO4	NO3	Fe	Mn	As	Cl rez	Colonii bact. 22 gr. C	Colonii bact. 37 gr. C	Coli-formi	E. coli	Entero-coci	miros	gust	culoare	
22.apr	958	4,77	1517	7,21	0,06	0,01	0,51	35,94	238,18	56,90	4,02	39	1388		0,11	0	0	0	0	0	0	0	0	0
16-mai	1259	5,18	2287	6,71	0,28	0,03	0,93	54,96	556,01	73,48	0,00	385	1009		0,10	0	0	0	0	0	0	0	0	0
29-aug	2219	5,40	1372	6,84	0,08	0	0,66	27,15	247,23	44,68	4,85	389	681		0,12	14	5	0	0	0	0	0	0	0
16-oct	2623	1,87	1518	6,9	0,02	0	0,89	27,52	225,12	44,60	4,20	509	1971		0,10	0	0	0	0	0	0	0	0	0
Min		1,87	1372	6,71	0,02	0	0,51	27,15	225,12	44,60	0,00	39	681		0,10	0	0	0	0	0	0	0	0	0
Med		4,31	1674	6,92	0	0	0,75	36,39	316,64	54,92	3,27	331	1262		0,11	4	1	0	0	0	0	0	0	0
Max		5,40	2287	7,21	0,28	0	0,93	54,96	556,01	73,48	4,85	509	1971		0,12	14	5	0	0	0	0	0	0	0
Nr. probe		4	4	4	4	4	4	4	4	4	4	4	4		4	4	4	4	4	4	4	4	4	4
Depășiri		2	0	0	0	0	0	0	1	0	0	3	4		0	0	0	0	0	0	0	0	0	0
% depășiri		50%	0%	0%	0%	0%	0%	0%	25%	0%	0%	75%	100%		0%	0%	0%	0%	0%	0%	0%	0%	0%	0%

SĂVĂRȘIN - rețea SĂVĂRȘIN , Liceu

Data	Cod	Turb	Cond	pH	NH4	NO2	CCOMn	Dt	Cl	SO4	NO3	Fe	Mn	As	Cl rez	Colonii bact. 22 gr. C	Colonii bact. 37 gr. C	Coli-formi	E. coli	Entero-coci	miros	gust	culoare	
22.apr	959	5,00	1544	7,22	0,03	0						67	1394		0,10	0	0	0	0	0	0	0	0	0
16-mai	1260	5,57	2272	6,78	0,25	0						355	1500		0,10	0	0	0	0	0	0	0	0	0
29-aug	2220	4,18	1378	6,89	0,06	0						309	666		0,10	19	7	0	0	0	0	0	0	0
16-oct	2624	2,17	1490	6,88	0,01	0,02						467	1888		0,10	0	0	0	0	0	0	0	0	0
Min		2,17	1378	6,78	0,01	0						67	666		0,10	0	0	0	0	0	0	0	0	0
Med		4,23	1671	6,94	0	0						300	1362		0,10	5	2	0	0	0	0	0	0	0
Max		5,57	2272	7,22	0	0						467	1888		0,10	19	7	0	0	0	0	0	0	0
Nr. probe		4	4	4	4	4						4	4		4	4	4	4	4	4	4	4	4	4
Depășiri		1	0	0	0	0						3	4		0	0	0	0	0	0	0	0	0	0
% depășiri		25%	0%	0%	0%	0%						75%	100%		0%	0%	0%	0%	0%	0%	0%	0%	0%	0%

TOTAL IR + CR

Data	Turb	Cond	pH	NH4	NO2	CCOMn	Dt	Cl	SO4	NO3	Fe	Mn	As	Cl rez	Colonii bact. 22 gr. C	Colonii bact. 37 gr. C	Coli- formi	E. coli	Entero- coci	miros	gust	culoare
Min	1,87	1372	6,71	0	0	0,51	27,15	225,12	44,60	0,00	39	666		0,10	0	0	0	0	0	0	0	0
Med	4,27	1672	6,93	0	0	0,75	36,39	316,64	54,92	3,27	315	1312		0,10	4	2	0	0	0	0	0	0
Max	5,57	2287	7,22	0,28	0,03	0,93	54,96	556,01	73,48	4,85	509	1971		0,12	19	7	0	0	0	0	0	0
Nr. probe	8	8	8	8	8	4	4	4	4	4	8	8		8	8	8	8	8	8	8	8	8
Depășiri	3	0	0	0	0	0	0	1	0	0	6	8		0	0	0	0	0	0	0	0	0
% depășiri	38%	0%	0%	0%	0%	0%	0%	25%	0%	0%	75%	100%		0%	0%	0%	0%	0%	0%	0%	0%	0%