

### ARAD UZINA Nr.3 - 2024

Valori max. admise Ordonanța nr.7 din 18.01.2023	Turbiditate	Cl <sub>2</sub>	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
	5	0,1 - 0,5	Fără modificări anormale	Fără modificări anormale	0	0	0
	NTU	mg/l	-	-	număr/ 100 ml	număr/ 100 ml	număr/ 100 ml

### ARAD UZINA 3, REZERVOR 1 - 2024

Data	Cod probă	Turbiditate	Cl <sub>2</sub>	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
13.03.2024	224	0.349	0.11	0	0	0	0	0
16.05.2024	538	0.182	0.20	0	0	0	0	0
Minim		0	0	0	0	0	0	0
Mediu		0	0	0	0	0	0	0
Maxim		0	0	0	0	0	0	0
Nr. probe		2	2	2	2	2	2	2
Depășiri		0	0	0	0	0	0	0
% Depășiri		0.00	0.00	0.00	0.00	0.00	0.00	0.00

### ARAD UZINA 3, REZERVOR 2 - 2024

Data	Cod probă	Turbiditate	Cl <sub>2</sub>	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
13.03.2024	225	0.296	0.11	0	0	0	0	0
16.05.2024	539	0.273	0.21	0	0	0	0	0
Minim		0	0	0	0	0	0	0
Mediu		0	0	0	0	0	0	0
Maxim		0	0	0	0	0	0	0
Nr. probe		2	2	2	2	2	2	2
Depășiri		0	0	0	0	0	0	0
% Depășiri		0.00	0.00	0.00	0.00	0.00	0.00	0.00

### NECESAR - 2024

	Turbiditate	Cl <sub>2</sub>	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
Necesar	6	6	6	6	6	6	6
Probe rămase	2	2	2	2	2	2	2