

ARAD, REȚEA DISTRIBUȚIE CĂLUGĂRENI - Casă particulară nr. 57 - 2024

Data	Cod probă	Culoare	Gust	Miros	Turbiditate	Conductivitate	pH	NH ₃	NO ₂	Oxidabilitate	Duritate	Cl ⁻	SO ₄ ²⁻	NO ₃ ⁻	Fe	Mn	As	Cl ₂	NTG 22°C	NTG 37 °C	Coliformi	E. coli	Enterococi
18.03.2024	243	0	0	0	0.202	501	7.45	0.00	0.00	0.74	15.91	26.06	30.68	34.18	12	0	0	0.10	0	0	0	0	0
27.03.2024	319	0	0	0	0.216	567	7.00	0.05	0.00	0.99	14.21	25.28	28.05	32.67	12	2	0	0.10	0	0	0	0	0
09.04.2024	363	0	0	0	0.206	578	7.01	0.00	0.00					37.05	26			0.14	0	0	0	0	0
24.04.2024	492	0	0	0	0.250	579	7.10	0.00	0.00	0.85	15.64	26.53	32.45	34.58	13	1	0	0.15	0	0	0	0	0
16.05.2024	544	0	0	0	0.351	610	7.28	0.00	0.00	0.79	14.96	29.93	32.40	34.21	20	1	0	0.10	0	0	0	0	0
22.05.2024	576	0	0	0	0.233	549	7.54	0.00	0.00					35.43	15			0.18	0	0	0	0	0
03.06.2024	603	0	0	0	0.187	531	7.49	0.00	0.00					30.09	15			0.10	0	0	0	0	0
18.06.2024	655	0	0	0	0.302	526	7.49	0.00	0.00					35.45	47			0.10	0	0	0	0	0
01.07.2024	672	0	0	0	0.320	592	7.63	0.04	0.00					34.60	17			0.10	0	0	0	0	0
08.08.2024	797	0	0	0	0.167	590	7.65	0.00	0.00					32.90	17			0.20	0	0	0	0	0
16.08.2024	805	0	0	0	0.266	575	7.26	0.00	0.00					29.07	13			0.16	0	0	0	0	0
23.08.2024	836	0	0	0	0.359	539	7.48	0.00	0.00					32.75	23			0.10	0	0	0	0	0
Minim		0	0	0	0	501	7	0	0	1	14	25	28	29	12	0	0	0	0	0	0	0	0
Mediu		0	0	0	0	561	7	0	0	1	15	27	31	34	19	1	0	0	0	0	0	0	0
Maxim		0	0	0	0	610	8	0	0	1	16	30	32	37	47	2	0	0	0	0	0	0	0
Nr. probe		12	12	12	12	12	12	12	12	4	4	4	4	12	12	4	4	12	12	12	12	12	12
Depășiri		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
% Depășiri		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NECESAR - 2024

	Culoare	Gust	Miros	Turbiditate	Conductivitate	pH	NH ₃	NO ₂	Oxidabilitate	Duritate	Cl ⁻	SO ₄ ²⁻	NO ₃ ⁻	Fe	Mn	As	Cl ₂	NTG 22°C	NTG 37 °C	Coliformi	E. coli	Enterococi	
Necesar	38	38	38	38	38	38	38	38	6	6	6	6	38	38	6	6	38	38	38	38	38	38	38
Probe rămase	12	12	12	12	12	12	12	12	-2	-2	-2	-2	12	12	-3	-2	12	12	12	12	12	12	12