

## LIPOVA - 2024

Valori max. admise Ordonanța nr.7 din 18.01.2023	Turbiditate	Cl <sub>2</sub>	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
	5	0,1 - 0,5	Fără modificări anormale	Fără modificări anormale	0	0	0
	NTU	mg/l	-	-	număr/ 100 ml	număr/ 100 ml	număr/ 100 ml

### LIPOVA, REZERVOR LIPOVA 1 - 2024

Data	Cod probă	Turbiditate	Cl <sub>2</sub>	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
20.03.2024	271	0.322	0.10	0	0	0	0	0
04.07.2024	691	0.374	0.33	0	0	0	0	0
Minim		0	0	0	0	0	0	0
Mediu		0	0	0	0	0	0	0
Maxim		0	0	0	0	0	0	0
Nr. probe		2	2	2	2	2	2	2
Depășiri		0	0	0	0	0	0	0
% Depășiri		0.00	0.00	0.00	0.00	0.00	0.00	0.00

### LIPOVA, REZERVOR LIPOVA 2 - 2024

Data	Cod probă	Turbiditate	Cl <sub>2</sub>	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
20.03.2024	272	0.333	0.10	0	0	0	0	0
04.07.2024	692	0.253	0.25	14	10	0	0	0
Minim		0	0	0	0	0	0	0
Mediu		0	0	7	5	0	0	0
Maxim		0	0	14	10	0	0	0
Nr. probe		2	2	2	2	2	2	2
Depășiri		0	0	0	0	0	0	0
% Depășiri		0.00	0.00	0.00	0.00	0.00	0.00	0.00

### NECESAR - 2024

	Turbiditate	Cl <sub>2</sub>	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
Necesar	6	6	6	6	6	6	6
Probe rămase	2	2	2	2	2	2	2