

PÂNCOTA, REZERVOR DUD - 2024

Data	Cod probă	Turbiditate	Cl ₂	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
05.03.2024	183	0.658	0.13	0	0	0	0	0
21.05.2024	568	0.561	0.15	0	0	0	0	0
Minim		1	0	0	0	0	0	0
Mediu		1	0	0	0	0	0	0
Maxim		1	0	0	0	0	0	0
Nr. probe		2	2	2	2	2	2	2
Depășiri		0	0	0	0	0	0	0
% Depășiri		0.00	0.00	0.00	0.00	0.00	0.00	0.00

NECESAR - 2024

	Turbiditate	Cl ₂	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
Necesar	6	6	6	6	6	6	6
Probe rămase	2	2	2	2	2	2	2