

SĂVÂRȘIN - 2024

Valori max. admise Ordonanța nr.7 din 18.01.2023	Turbiditate	Cl ₂	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
	5	0,1 - 0,5	Fără modificări anormale	Fără modificări anormale	0	0	0
	NTU	mg/l	-	-	număr/ 100 ml	număr/ 100 ml	număr/ 100 ml

SĂVÂRȘIN, REZERVOR SĂVÂRȘIN - 2024

Data	Cod probă	Turbiditate	Cl ₂	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
20.03.2024	276	1.390	0.11	0	0	0	0	0
04.07.2024	693	1.310	0.10	0	11	0	0	0
Minim		1	0	0	0	0	0	0
Mediu		1	0	0	6	0	0	0
Maxim		1	0	0	11	0	0	0
Nr. probe		2	2	2	2	2	2	2
Depășiri		0	0	0	0	0	0	0
% Depășiri		0.00	0.00	0.00	0.00	0.00	0.00	0.00

NECESAR - 2024

	Turbiditate	Cl ₂	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
Necesar	3	3	3	3	3	3	3
Probe rămase	1	1	1	1	1	1	1