

CURTICI, REȚEA DISTRIBUȚIE VARIAȘUL MARE - Grădiniță cu program normal Variașu Mare, nr.117 - 2024

Data	Cod probă	Culoare	Gust	Miros	Turbiditate	Conductivitate	pH	NH ₃ -	NO ₂ -	Oxidabilitate	Duritate	Cl-	SO ₄ 2-	NO ₃ -	Fe	Mn	As	Cl ₂	NTG 22°C	NTG 37 °C	Coliformi	E. coli	Enterococi
18.04.2024	446	0	0	0	0.530	625	7.47	0.00	0.00	0.80	16.07	8.48	17.62	8.01	13	2	0	0.10	0	0	0	0	0
08.07.2024	710	0	0	0	0.222	627	7.44	0.00	0.00	0.76	17.27	8.41	17.57	8.05	11	4	0	0.10	1	0	0	0	0
16.09.2024	875	0	0	0	0.130	628	7.50	0.00	0.00	0.89	16.30	6.96	19.88	13.99	43	1		0.12	0	0	0	0	0
Minim		0	0	0	0	625	7	0	0	1	16	7	18	8	11	1	0	0	0	0	0	0	0
Mediu		0	0	0	0	627	7	0	0	1	17	8	18	10	22	2	0	0	0	0	0	0	0
Maxim		0	0	0	1	628	8	0	0	1	17	8	20	14	43	4	0	0	1	0	0	0	0
Nr. probe		3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	2	3	3	3	3	3	3
Depășiri		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
% Depășiri		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NECESAR - 2024

	Culoare	Gust	Miros	Turbiditate	Conductivitate	pH	NH ₃ -	NO ₂ -	Oxidabilitate	Duritate	Cl-	SO ₄ 2-	NO ₃ -	Fe	Mn	As	Cl ₂	NTG 22°C	NTG 37 °C	Coliformi	E. coli	Enterococi	
Necesar	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6
Probe rămase	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	0	0	0	0	0	0	0