

FELNAC, REȚEA DISTRIBUȚIE FELNAC - Școala gimnazială "Aurel Sebeșan" Felnac nr.397 - 2024

Data	Cod probă	Culoare	Gust	Miros	Turbiditate	Conductivitate	pH	NH ₃ -	NO ₂ -	Oxidabilitate	Duritate	Cl-	SO ₄ 2-	NO ₃ -	Fe	Mn	As	Cl ₂	NTG 22°C	NTG 37 °C	Coliformi	E. coli	Enterococi
11.04.2024	392	0	0	0	0.226	655	7.38	0.00	0.00	0.89	21.92	11.25	13.38	35.26	5	0	0	0.38	0	0	0	0	0
08.08.2024	801	0	0	0	0.141	654	7.39	0.00	0.00	1.02	20.26	13.59	13.21	35.08	10	1	0	0.17	0	0	0	0	0
03.10.2024	962	0	0	0	0.159	654	7.45	0.00	0.00	0.80	19.26	11.01	14.84	37.85	22	2		0.10	0	0	0	0	0
Minim		0	0	0	0	654	7	0	0	1	19	11	13	35	5	0	0	0	0	0	0	0	0
Mediu		0	0	0	0	654	7	0	0	1	20	12	14	36	12	1	0	0	0	0	0	0	0
Maxim		0	0	0	0	655	7	0	0	1	22	14	15	38	22	2	0	0	0	0	0	0	0
Nr. probe		3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	2	3	3	3	3	3	3
Depășiri		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
% Depășiri		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NECESAR - 2024

	Culoare	Gust	Miros	Turbiditate	Conductivitate	pH	NH ₃ -	NO ₂ -	Oxidabilitate	Duritate	Cl-	SO ₄ 2-	NO ₃ -	Fe	Mn	As	Cl ₂	NTG 22°C	NTG 37 °C	Coliformi	E. coli	Enterococi
Necesar	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6
Probe rămase	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	0	0	0	0	0	0