

HĂLMĂGEL - 2024

Valori max. admise Ordonanța nr.7 din 18.01.2023	Turbiditate	Cl ₂	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
	5	0,1 - 0,5	Fără modificări anormale	Fără modificări anormale	0	0	0
	NTU	mg/l	-	-	număr/ 100 ml	număr/ 100 ml	număr/ 100 ml

HĂLMĂGEL, REZERVOR HĂLMĂGEL - 2024

Data	Cod probă	Turbiditate	Cl ₂	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
23.04.2024	487	0.919	0.11	0	0	0	0	0
17.06.2024	651	0.917	0.12	0	0	0	0	0
Minim		1	0	0	0	0	0	0
Mediu		1	0	0	0	0	0	0
Maxim		1	0	0	0	0	0	0
Nr. probe		2	2	2	2	2	2	2
Depășiri		0	0	0	0	0	0	0
% Depășiri		0.00	0.00	0.00	0.00	0.00	0.00	0.00

HĂLMĂGEL, REZERVOR VÂRFURILE - 2024

Data	Cod probă	Turbiditate	Cl ₂	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
23.04.2024	488	0.840	0.15	0	0	0	0	0
17.06.2024	652	0.874	0.11	0	0	0	0	0
Minim		1	0	0	0	0	0	0
Mediu		1	0	0	0	0	0	0
Maxim		1	0	0	0	0	0	0
Nr. probe		2	2	2	2	2	2	2
Depășiri		0	0	0	0	0	0	0
% Depășiri		0.00	0.00	0.00	0.00	0.00	0.00	0.00

NECESAR - 2024

	Turbiditate	Cl ₂	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
Necesar	6	6	6	6	6	6	6
Probe rămase	2	2	2	2	2	2	2