

MONEASA - 2024

Valori max. admise Ordonanța nr.7 din 18.01.2023	Turbiditate	Cl ₂	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
	5	0,1 - 0,5	Fără modificări anormale	Fără modificări anormale	0	0	0
	NTU	mg/l	-	-	număr/ 100 ml	număr/ 100 ml	număr/ 100 ml

MONEASA, REZERVOR MONEASA - 2024

Data	Cod probă	Turbiditate	Cl ₂	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
19.03.2024	259	0.790	0.10	0	0	0	0	0
29.04.2024	502	0.838	0.44	0	0	0	0	0
17.09.2024	911	0.282	0.40	0	0	0	0	0
Minim		0	0	0	0	0	0	0
Mediu		1	0	0	0	0	0	0
Maxim		1	0	0	0	0	0	0
Nr. probe		3	3	3	3	3	3	3
Depășiri		0	0	0	0	0	0	0
% Depășiri		0.00	0.00	0.00	0.00	0.00	0.00	0.00

MONEASA, REZERVOR SLATINA DE CRIȘ - 2024

Data	Cod probă	Turbiditate	Cl ₂	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
19.03.2024	260	0.444	0.10	0	0	0	0	0
29.04.2024	507	0.574	0.40	0	0	0	0	0
17.09.2024	912	0.550	0.10	0	0	0	0	0
Minim		0	0	0	0	0	0	0
Mediu		1	0	0	0	0	0	0
Maxim		1	0	0	0	0	0	0
Nr. probe		3	3	3	3	3	3	3
Depășiri		0	0	0	0	0	0	0
% Depășiri		0.00	0.00	0.00	0.00	0.00	0.00	0.00

NECESAR - 2024

	Turbiditate	Cl ₂	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
Necesar	6	6	6	6	6	6	6
Probe rămase	0	0	0	0	0	0	0