

## PECICA - 2024

Valori max. admise Ordonanța nr.7 din 18.01.2023	Turbiditate	Cl <sub>2</sub>	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
	5	0,1 - 0,5	Fără modificări anormale	Fără modificări anormale	0	0	0
	NTU	mg/l	-	-	număr/ 100 ml	număr/ 100 ml	număr/ 100 ml

### PECICA, REZERVOR PECICA 1 - 2024

Data	Cod probă	Turbiditate	Cl <sub>2</sub>	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
11.04.2024	403	0.383	0.45	0	0	0	0	0
22.08.2024	823	0.250	0.23	0	0	0	0	0
02.10.2024	940	0.153	0.25	0	0	0	0	0
Minim		0	0	0	0	0	0	0
Mediu		0	0	0	0	0	0	0
Maxim		0	0	0	0	0	0	0
Nr. probe		3	3	3	3	3	3	3
Depășiri		0	0	0	0	0	0	0
% Depășiri		0.00	0.00	0.00	0.00	0.00	0.00	0.00

### PECICA, REZERVOR PECICA 2 - 2024

Data	Cod probă	Turbiditate	Cl <sub>2</sub>	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
11.04.2024	404	0.389	0.48	0	0	0	0	0
22.08.2024	824	0.275	0.23	0	0	0	0	0
02.10.2024	941	0.266	0.26	0	0	0	0	0
Minim		0	0	0	0	0	0	0
Mediu		0	0	0	0	0	0	0
Maxim		0	0	0	0	0	0	0
Nr. probe		3	3	3	3	3	3	3
Depășiri		0	0	0	0	0	0	0
% Depășiri		0.00	0.00	0.00	0.00	0.00	0.00	0.00

### NECESAR - 2024

	Turbiditate	Cl <sub>2</sub>	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
Necesar	6	6	6	6	6	6	6
Probe rămase	0	0	0	0	0	0	0