

PEREGU MARE - 2024

	Turbiditate	Cl ₂	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
Valori max. admise Ordonanța nr.7 din 18.01.2023	5	0,1 - 0,5	Fără modificări anormale	Fără modificări anormale	0	0	0
	NTU	mg/l	-	-	număr/ 100 ml	număr/ 100 ml	număr/ 100 ml

PEREGU MARE, REZERVOR PEREGU MARE - 2024

Data	Cod probă	Turbiditate	Cl ₂	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
16.05.2024	543	0.429	0.15	0	0	0	0	0
22.08.2024	833	0.409	0.10	0	0	0	0	0
02.10.2024	948	0.769	0.28	0	0	0	0	0
Minim		0	0	0	0	0	0	0
Mediu		1	0	0	0	0	0	0
Maxim		1	0	0	0	0	0	0
Nr. probe		3	3	3	3	3	3	3
Depășiri		0	0	0	0	0	0	0
% Depășiri		0.00	0.00	0.00	0.00	0.00	0.00	0.00

NECESAR - 2024

	Turbiditate	Cl ₂	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
Necesar	3	3	3	3	3	3	3
Probe rămase	0	0	0	0	0	0	0