

ARAD UZINA 3, REZERVOR 2 - 2024

| Data | Cod probă | Turbiditate | Cl ₂ | NTG 22°C | NTG 37°C | Coliformi | E. coli | Enterococi |
|------------|-----------|-------------|-----------------|----------|----------|-----------|---------|------------|
| 13.03.2024 | 225 | 0.296 | 0.11 | 0 | 0 | 0 | 0 | 0 |
| 16.05.2024 | 539 | 0.273 | 0.21 | 0 | 0 | 0 | 0 | 0 |
| 09.07.2024 | 723 | 0.173 | 0.11 | 0 | 0 | 0 | 0 | 0 |
| Minim | | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Mediu | | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Maxim | | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Nr. probe | | 3 | 3 | 3 | 3 | 3 | 3 | 3 |
| Depășiri | | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| % Depășiri | | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

NECESAR - 2024

| | Turbiditate | Cl ₂ | NTG 22°C | NTG 37°C | Coliformi | E. coli | Enterococi |
|--------------|-------------|-----------------|----------|----------|-----------|---------|------------|
| Necesar | 6 | 6 | 6 | 6 | 6 | 6 | 6 |
| Probe rămase | 0 | 0 | 0 | 0 | 0 | 0 | 0 |