

CĂSOAIA - 2024

Valori max. admise Ordonanța nr.7 din 18.01.2023	Turbiditate	Cl ₂	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
	5	0,1 - 0,5	Fără modificări anormale	Fără modificări anormale	0	0	0
	NTU	mg/l	-	-	număr/ 100 ml	număr/ 100 ml	număr/ 100 ml

CĂSOAIA, REZERVOR CĂSOAIA - 2024

Data	Cod probă	Turbiditate	Cl ₂	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
22.04.2024	468	0.230	0.10	1	0	0	0	0
17.06.2024	641	0.270	0.10	0	2	0	0	0
15.10.2024	1007	0.807	0.11	0	0	0	0	0
Minim		0	0	0	0	0	0	0
Mediu		0	0	0	1	0	0	0
Maxim		1	0	1	2	0	0	0
Nr. probe		3	3	3	3	3	3	3
Depășiri		0	0	0	0	0	0	0
% Depășiri		0.00	0.00	0.00	0.00	0.00	0.00	0.00

NECESAR - 2024

	Turbiditate	Cl ₂	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
Necesar	3	3	3	3	3	3	3
Probe rămase	0	0	0	0	0	0	0