

PÂNCOTA - 2024

Valori max. admise Ordonanța nr.7 din 18.01.2023	Turbiditate	Cl ₂	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
	5	0,1 - 0,5	Fără modificări anormale	Fără modificări anormale	0	0	0
	NTU	mg/l	-	-	număr/ 100 ml	număr/ 100 ml	număr/ 100 ml

PÂNCOTA, REZERVOR PÂNCOTA - 2024

Data	Cod probă	Turbiditate	Cl ₂	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
05.03.2024	184	0.411	0.15	0	0	0	0	0
21.05.2024	567	0.256	0.20	0	0	0	0	0
17.09.2024	897	0.278	0.10	2	0	0	0	0
Minim		0	0	0	0	0	0	0
Mediu		0	0	1	0	0	0	0
Maxim		0	0	2	0	0	0	0
Nr. probe		3	3	3	3	3	3	3
Depășiri		0	0	0	0	0	0	0
% Depășiri		0.00	0.00	0.00	0.00	0.00	0.00	0.00

PÂNCOTA, REZERVOR DUD - 2024

Data	Cod probă	Turbiditate	Cl ₂	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
05.03.2024	183	0.658	0.13	0	0	0	0	0
21.05.2024	568	0.561	0.15	0	0	0	0	0
17.09.2024	898	0.242	0.10	0	0	0	0	0
Minim		0	0	0	0	0	0	0
Mediu		0	0	0	0	0	0	0
Maxim		1	0	0	0	0	0	0
Nr. probe		3	3	3	3	3	3	3
Depășiri		0	0	0	0	0	0	0
% Depășiri		0.00	0.00	0.00	0.00	0.00	0.00	0.00

NECESAR - 2024

	Turbiditate	Cl ₂	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
Necesar	6	6	6	6	6	6	6
Probe rămase	0	0	0	0	0	0	0