

## SÂNTANA - 2024

Valori max. admise Ordonanța nr.7 din 18.01.2023	Turbiditate	Cl <sub>2</sub>	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
	5	0,1 - 0,5	Fără modificări anormale	Fără modificări anormale	0	0	0
	NTU	mg/l	-	-	număr/ 100 ml	număr/ 100 ml	număr/ 100 ml

### SÂNTANA, REZERVOR SÂNTANA 1 - 2024

Data	Cod probă	Turbiditate	Cl <sub>2</sub>	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
18.04.2024	452	0.137	0.11	0	0	0	0	0
08.07.2024	716	0.282	0.12	0	0	0	0	0
Minim		0	0	0	0	0	0	0
Mediu		0	0	0	0	0	0	0
Maxim		0	0	0	0	0	0	0
Nr. probe		2	2	2	2	2	2	2
Depășiri		0	0	0	0	0	0	0
% Depășiri		0.00	0.00	0.00	0.00	0.00	0.00	0.00

### SÂNTANA, REZERVOR SÂNTANA 2 - 2024

Data	Cod probă	Turbiditate	Cl <sub>2</sub>	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
18.04.2024	453	0.141	0.11	0	0	0	0	0
08.07.2024	717	0.166	0.13	0	0	0	0	0
Minim		0	0	0	0	0	0	0
Mediu		0	0	0	0	0	0	0
Maxim		0	0	0	0	0	0	0
Nr. probe		2	2	2	2	2	2	2
Depășiri		0	0	0	0	0	0	0
% Depășiri		0.00	0.00	0.00	0.00	0.00	0.00	0.00

### NECESAR - 2024

	Turbiditate	Cl <sub>2</sub>	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
Necesar	6	6	6	6	6	6	6
Probe rămase	2	2	2	2	2	2	2