

ȘEPREUȘ - 2024

	Turbiditate	Cl ₂	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
Valori max. admise Ordonanța nr.7 din 18.01.2023	5	0,1 - 0,5	Fără modificări anormale	Fără modificări anormale	0	0	0
	NTU	mg/l	-	-	număr/ 100 ml	număr/ 100 ml	număr/ 100 ml

ȘEPREUȘ, REZERVOR ȘEPREUȘ - 2024

Data	Cod probă	Turbiditate	Cl ₂	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
16.04.2024	430	0.458	0.22	0	0	0	0	0
25.07.2024	774	0.760	0.13	0	2	0	0	0
18.11.2024	1160	3.280	0.42	0	0	0	0	0
Minim		0	0	0	0	0	0	0
Mediu		1	0	0	1	0	0	0
Maxim		3	0	0	2	0	0	0
Nr. probe		3	3	3	3	3	3	3
Depășiri		0	0	0	0	0	0	0
% Depășiri		0.00	0.00	0.00	0.00	0.00	0.00	0.00

NECESAR - 2024

	Turbiditate	Cl ₂	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
Necesar	3	3	3	3	3	3	3
Probe rămase	0	0	0	0	0	0	0