

## VINGA - 2024

Valori max. admise Ordonanța nr.7 din 18.01.2023	Turbiditate	Cl <sub>2</sub>	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
	5	0,1 - 0,5	Fără modificări anormale	Fără modificări anormale	0	0	0
	NTU	mg/l	-	-	număr/ 100 ml	număr/ 100 ml	număr/ 100 ml

### VINGA, REZERVOR VINGA 1 - 2024

Data	Cod probă	Turbiditate	Cl <sub>2</sub>	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
10.04.2024	384	0.458	0.10	0	0	0	0	0
05.06.2024	616	0.782	0.10	0	0	0	0	0
19.08.2024	812	1.100	0.10	0	0	0	0	0
Minim		0	0	0	0	0	0	0
Mediu		1	0	0	0	0	0	0
Maxim		1	0	0	0	0	0	0
Nr. probe		3	3	3	3	3	3	3
Depășiri		0	0	0	0	0	0	0
% Depășiri		0.00	0.00	0.00	0.00	0.00	0.00	0.00

### VINGA, REZERVOR VINGA 2 - 2024

Data	Cod probă	Turbiditate	Cl <sub>2</sub>	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
10.04.2024	385	0.689	0.10	0	0	0	0	0

05.06.2024	617	0.398	0.10	0	0	0	0	0
19.08.2024	813	0.328	0.10	0	0	0	0	0
Minim	0	0	0	0	0	0	0	0
Mediu	0	0	0	0	0	0	0	0
Maxim	1	0	0	0	0	0	0	0
Nr. probe	3	3	3	3	3	3	3	3
Depășiri	0	0	0	0	0	0	0	0
% Depășiri	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

### VINGA, REZERVOR VINGA 3 - 2024

Data	Cod probă	Turbiditate	Cl <sub>2</sub>	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
10.04.2024	386	0.822	0.10	0	0	0	0	0
05.06.2024	618	0.818	0.10	0	0	0	0	0
19.08.2024	814	0.544	0.10	0	0	0	0	0
Minim	1	0	0	0	0	0	0	0
Mediu	1	0	0	0	0	0	0	0
Maxim	1	0	0	0	0	0	0	0
Nr. probe	3	3	3	3	3	3	3	3
Depășiri	0	0	0	0	0	0	0	0
% Depășiri	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

### VINGA, REZERVOR CRUCENI - 2024

Data	Cod probă	Turbiditate	Cl <sub>2</sub>	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
10.04.2024	383	0.767	0.20	0	0	0	0	0
05.06.2024	619	0.189	0.10	0	0	0	0	0
19.08.2024	815	0.804	0.14	0	0	0	0	0
Minim	0	0	0	0	0	0	0	0
Mediu	1	0	0	0	0	0	0	0
Maxim	1	0	0	0	0	0	0	0
Nr. probe	3	3	3	3	3	3	3	3
Depășiri	0	0	0	0	0	0	0	0
% Depășiri	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

### NECESAR - 2024

	Turbiditate	Cl <sub>2</sub>	NTG 22°C	NTG 37°C	Coliformi	E. coli	Enterococi
Necesar	12	12	12	12	12	12	12
Probe rămase	0	0	0	0	0	0	0